

- \_\_\_ 95. Smoke detection is required. A/C powered smoke detectors shall be installed in all dwelling units of OBBC Use Group R-2 and R-3 in accordance with OBBC Section 919.3.2 and NFIPA 74. They shall be interconnected as detailed in Section 919.4. These smoke detection units are required to be primary source A/C powered and shall receive power from a battery (Section 919.5) when A/C primary source power is interrupted. Acceptance (witness) testing is required by Section 919.6. (NOTE: Also see Section 904.9 for other possible requirements.
- \_\_\_ 96. Receptacles for laundry (washer, dryer, etc.), or other separate circuit requirements shall be a single opening type to comply with Columbus Building Code 4159.06.

X. OTHER ITEMS