

J. MECHANICAL REFRIGERATION (CHAPTER 13)

__ 85. See memorandum attached to drawings.

K. SPECIAL CONDITIONS OR LOCATIONS

__ 90. Provide furnace, incinerator, and boiler room with 2 egress doorways when area exceeds 500 sq. ft. and individual fuel fired equipment exceeds 400,000 BTUs input capacity. Separate doorways with horizontal distances not less than $\frac{1}{2}$ the diagonal dimension of the room, fixed ladder access out of the room is permitted in lieu of one doorway, see OBBC 1017.2, exception 2.

__ 91. Components of pre-fabricated paint spray boot must be listed by a recognized testing laboratory, provide documentation of listing. See NfiPA 33-34. Paint storage must comply with OBBC 419.21.3 and NfiPA 30. A separate permit is required for spray booths. Contact the Fire Prevention Bureau at 645-7641.

L. ENERGY CONSERVATIO (CHAPTER 13 OF OBBC)

__ 95. Provide energy analysis as required by OBBC Chapter 13 for review and approval.

M. COLUMBUS BUILDING CODE

__ 96. Condensation discharge from the units is required to comply with Columbus Building Code 4149.23 or the new Ohio Basic Mechanical Code Section 307.2.1.